

Schools FLAGEL Report for: Example Primary School

Report Date:	02/07/2025
Data Date:	01/07/2025
Site Head:	Mrs Head Teacher
Site SBM:	Site SBM
Site Manager:	Site Manager
Concerto Users:	SBM & Site Manager
Other Concerto User:	n/a

Overview and Score:

FLAGEL documents are:

- | | |
|-------------------------------|---|
| 1. Fire Risk Assessment | 4. Gas Servicing/Safety |
| 2. Legionella Risk Assessment | 5. Electrical Installation Condition Report |
| 3. Asbestos Management Plan | 6. Lift Servicing (if applicable) |

This report shows the position of Example Primary School on the above date. Data is taken from Ealing Council's Concerto site and reflects the status of FLAGEL documents and associated remedials. The maximum FLAGEL score is 100. The range of scores for 63 sites on the data date was -50 to 100. The average score was 61.4.

Example Primary School	
FLAGEL Score: 95.5	FLAGEL Rank: 3/63

Documents:

Item	Overdue	Expiry
1. Fire Risk Assessment	No	21/11/2025
2. Legionella Risk Assessment	No	28/05/2027
3. Asbestos Management Plan	No	18/09/2025
4. Gas Servicing/Safety	No	01/05/2026
5. Electrical Installation Condition Report	No	30/10/2025
6. Lift Servicing (if applicable)	No	30/11/2025

Overdue Remedials:

This table shows only **overdue** remedials. This means remedials that have passed the target date without being marked as completed.

Total of Overdue Remedials by Priority and Category:

Overdue	Fire	Legionella	Asbestos	Gas	Electrical	Lifts
Urgent (P0)	0	0	0	0	0	0
High (P1)	0	0	0	0	0	0
Medium (P2)	3	0	0	0	0	0
Low (P3/4)	0	0	0	0	0	0

For details of these remedials please [see the next page](#).

Remedials should be updated by the school within the Concerto remedials page.

Remedial Details:

Overdue remedials are listed below the count for each priority level.

Urgent Remedials (P0): 0

High Priority Remedials (P1): 0

Medium Priority Remedials (P2): 3

Category: FLAGEL Fire Risk Assessment	Concerto Ref: 16932
Status: With Site	Priority: P2 - 3 Months
Remedial Details: 13 - Section I - Fire awareness training should be refreshed periodically. Medium	
Date Identified: 21/11/2024	Target Date: 21/02/2025

Category: FLAGEL Fire Risk Assessment	Concerto Ref: 16925
Status: With Site	Priority: P2 - 3 Months
Remedial Details: 6 - Section C - Carry out the required remedial works as detailed in the fire door remedial list table. Medium	
Date Identified: 21/11/2024	Target Date: 21/02/2025

Category: FLAGEL Fire Risk Assessment	Concerto Ref: 16931
Status: With Site	Priority: P2 - 3 Months
Remedial Details: 12 - Section I - All staff should be provided with fire awareness training. Medium	
Date Identified: 21/11/2024	Target Date: 21/02/2025

Lower Priority Remedials (P3/4): 0